



# CERTIFICATE OF PRODUCT CERTIFICATION

**CERTIFICATE NO.:** CQC19012234177

**Valid from:** Jun.21,2022

**Valid until:**long-term

**NAME AND REGISTERED ADDRESS OF THE APPLICANT** Huanyu High Tech. Co. , Ltd.  
Wenzhou Bridge Industrial Zone, Yueqing City, Zhejiang Province, P.R.China

**NAME AND REGISTERED ADDRESS OF THE MANUFACTURER** Huanyu High Tech. Co. , Ltd.  
Wenzhou Bridge Industrial Zone, Yueqing City, Zhejiang Province, P.R.China

**NAME AND LOCATION OF THE FACTORY** Huanyu High Tech. Co. , Ltd.  
Wenzhou Bridge Industrial Zone, Yueqing, Zhejiang Province, P.R.China

**PRODUCT NAME, MODEL AND SPECIFICATION** External Circuit-breakers for Electricity Meters  
HUM18-M100SRN ; Ue : AC230V ; Ui : 500V ; Uimp : 6kV ; In : 6A, 10A, 16A, 20A, 25A, 32A, 40A, 50A, 63A, 80A, 100A ; Ics : 6000A , Icn : 6000A ; Type : C ; Poles:1P+N(with one protected pole,switched N pole);Remote automatic control mode and semi-automatic control mode;Uc:AC220V

**THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS** CQC1121-2016;GB/T 10963.1-2020

**TYPE OF CERTIFICATION SCHEMES** Type Testing of Product + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462187-2016.

Date of original issued: Dec.11,2019

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body.

The certificate information is available through the QR code below or CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE