

IEC**IECEE**
CB
SCHEME

Ref. Certif. No.

CN49787

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Residual Current Operated Circuit Breaker

Name and address of the applicant

Huanyu Group Zhejiang High Tech Co., Ltd.
Wenzhou Bridge Industrial Zone, Yueqing, Zhejiang Province,
P.R.China

Name and address of the manufacturer

Huanyu Group Zhejiang High Tech Co., Ltd.
Wenzhou Bridge Industrial Zone, Yueqing, Zhejiang Province,
P.R.China

Name and address of the factory

Huanyu Group Zhejiang High Tech Co., Ltd.
Wenzhou Bridge Industrial Zone, Yueqing, Zhejiang Province,
P.R.China*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

See the Appendix

Trademark (if any)

HUYU

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

DZ47NLE-63,DZ47NLG-63,DZ47NLE-63H,DZ47eLE-63,DZ
47eLG-63,DZ47eLE-63H,EXB3LE-63,EXB3LG-63,EXB3LE-
63H,EXB3eLE-63,EXB3eLG-63,EXB3eLE-63H;

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 61009-1:2010(3rd Edition) + AMD 1:2012;IEC
61009-2-2:1991(1st Edition)

As shown in the Test Report Ref. No. which forms part of this Certificate

03601-A-19CB0109-S

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRESection 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>

Date: Mar.25,2020

Signature:

Lu Mei

CB . 0050200

DZ47NLE-63, DZ47NLG-63, DZ47NLE-63H, DZ47eLE-63, DZ47eLG-63, DZ47eLE-63H,
EXB3LE-63, EXB3LG-63, EXB3LE-63H, EXB3eLE-63, EXB3eLG-63, EXB3eLE-63H;

U_i : 500V; U_{imp} : 4kV;

U_e : AC220V, 230V, 240V(1P+N, 2P), AC380V, 400V, 415V(3P, 3P+N, 4P);

I_n : 6A, 10A, 16A, 20A, 25A, 32A, 40A, 50A, 63A;

Instantaneous tripping current:

DZ47NLE-63, DZ47NLE-63H, DZ47eLE-63, DZ47eLE-63H, EXB3LE-63, EXB3eLE-63,
EXB3LE-63H, EXB3eLE-63H: Type B, Type C, Type D;

DZ47NLG-63, DZ47eLG-63, EXB3LG-63, EXB3eLG-63: Type C;

I_{cs} : 6kA(DZ47NLE-63, DZ47NLG-63, DZ47eLE-63, DZ47eLG-63, EXB3LE-63, EXB3LG-63,
EXB3eLE-63, EXB3eLG-63);

7.5kA(DZ47NLE-63H, DZ47eLE-63H, EXB3LE-63H, EXB3eLE-63H);

I_{cn} : 6kA(DZ47NLE-63, DZ47NLG-63, DZ47eLE-63, DZ47eLG-63, EXB3LE-63, EXB3LG-63,
EXB3eLE-63, EXB3eLG-63);

10kA(DZ47NLE-63H, DZ47eLE-63H, EXB3LE-63H, EXB3eLE-63H);

$I_{\Delta n}$: 30mA, 50mA, 75mA, 100mA, 300mA(Type AC);

Electronic Type;

$I_{\Delta m}$: 630A;

DZ47NLE-63, DZ47eLE-63, EXB3LE-63, EXB3eLE-63: 1P+N(1protected pole with an
uninterrupted neutral pole, not suitable for isolation), 2P, 3P, 3P+N(3protected pole with an
uninterrupted neutral pole, not suitable for isolation), 4P;

DZ47NLG-63, DZ47eLG-63, EXB3LG-63, EXB3eLG-63: 1P+N(1protected pole with an
uninterrupted neutral pole, not suitable for isolation), 2P;


DZ47NLE-63H, DZ47eLE-63H, EXB3LE-63H, EXB3eLE-63H: 2P

Additional information (if necessary)

Date:

Mar.25.2020

Signature:



Lu Mei