



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE200306007011

Product

Automatic Transfer Switching Equipments

Applicant

Huanyu Group Zhejiang High Tech Co., Ltd.
Wenzhou Bridge Industrial Zone, Yueqing, Zhejiang
Province, P.R.China

Type/Model

HYT3-63

Technical data

Uimp:4kV; Ui:500V(Main),400V(Control);
Ue:AC230V(2P),AC400V(3P,4P);
Ie:10A,16A,20A,25A,32A,40A,50A,63A; AC-32B; ATSE;
Icn:6kA; Icm:9.18kA; 2P,3P,4P

This is to certify that, on the basis of the tests undertaken as per Report No.
C-14201-DC198357, the submitted sample(s) of the above item complies with:

EN 60947-6-1:2005 + A1:2014

and fulfills testing requirements of the European Directive:

Low Voltage Directive(LVD): 2014/35/EU

Valid from: Nov.18,2020

Valid until: Nov.18,2023

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE
Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>