

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC22107354851

Valid from: Aug.11,2022

Valid until: Mar.16,2031

NAME AND REGISTERED ADDRESS OF THE APPLICANT	Huanyu Group Company Ltd. Wenzhou Daqiao Industrial Zone, Beibaixiang, Yueqing, Zhejiang Province, P.R.China
NAME AND REGISTERED ADDRESS OF THE MANUFACTURER	Huanyu Group Company Ltd. Wenzhou Daqiao Industrial Zone, Beibaixiang, Yueqing, Zhejiang Province, P.R.China
NAME AND LOCATION OF THE FACTORY	Huanyu High Tech. Co., Ltd. Wenzhou Bridge Industrial Zone, Yueqing, Zhejiang Province, P.R.China
PRODUCT NAME, MODEL AND SPECIFICATION	Air Circuit-breaker DW45-4000 ; Uimp :12kV ;Ui :1000V ;Ue :AC400V/690V ; In :2500A ,2900A ,3200A ,4000A ; 过电流脱扣器类型：电子式；AC400V：Ics：100kA，Icu：100kA，Icw：100kA/1s；AC690V：Ics：70kA，Icu：70kA，Icw：70kA/1s；选择性类别：B；3P、4P；适用于隔离用 配用的辅助触头 YQF1：4NO4NC；Uimp：4kV；Ui：400V，Ith：10A，AC-15：230V/1.5A，400V/0.9A；DC-13：220V/0.27A；符合附录 N 的电子附件：欠电压脱扣器 Uimp：12kV；Ui：690V；Us：AC230V，400V
THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS	GB/T 14048.2-2020
TYPE OF CERTIFICATION SCHEMES	Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

杨志刚

SIGNATURE

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE