

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC22107355478

Valid from: Aug.16,2022

Valid until: Jul.22,2031

NAME AND REGISTERED ADDRESS OF THE APPLICANT Huanyu Group Company Ltd.
Wenzhou Daqiao Industrial Zone, Beibaixiang, Yueqing, Zhejiang Province, P.R.China

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER Huanyu Group Company Ltd.
Wenzhou Daqiao Industrial Zone, Beibaixiang, Yueqing, Zhejiang Province, P.R.China

NAME AND LOCATION OF THE FACTORY Huanyu High Tech. Co., Ltd.
Wenzhou Bridge Industrial Zone, Yueqing, Zhejiang Province, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION Residual Current Operated Circuit-breaker With Integral Overcurrent Protection
DZ47NLE-125、DZ47eLE-125、DZ47LEK-125、HUB9iLE-125、HYB5LE-125; Ue :AC230V(1P+N , 2P) , AC400V(3P , 3P+N , 4P) ; Ui : 500V ; Uimp : 4kV ; In : 63A、80A、100A、125A ; Thermal Magnetic Over-current Release ; Ics : 7.5kA ; Icu : 10kA ; I_n : 30mA , 50mA , 75mA , 100mA , 150mA , 200mA , 300mA ; Electronic Residual Current Tripping Unit ; Rated Residual Operating Type : AC/A、 Non-time-delay ; Selectivity categories : A ; I_m : 2.5kA; Poles : 1P+N(With one protective poles,Uninterrupted N Pole) , 2P , 3P , 3P+N(With three protective poles,Uninterrupted N Pole) , 4P ; 2P、3P、4P Suitable for isolation , 1P+N、3P+N Not-suitable for isolation;See the Appendix for type explanation

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB/T 14048.2-2020

TYPE OF CERTIFICATION SCHEMES Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

SIGNATURE



CHINA QUALITY CERTIFICATION CENTRE