



产品认证证书

证书编号：CQC2018010308065741

申请人名称及地址

环宇集团浙江高科股份有限公司
浙江省乐清市温州大桥工业园区

制造商名称及地址

环宇集团浙江高科股份有限公司
浙江省乐清市温州大桥工业园区

生产企业名称及地址

上联控股集团有限公司(V029433)
浙江省乐清市柳市镇岙底村中南一路20号

产品名称和系列、规格、型号

有填料封闭管式熔断器

RT0-1000; 熔断体额定电压 Un: AC400V; 熔断体额定电流 In: 630A, 800A, 1000A; 额定分断能力 I1: 50kA; 分断范围和使用类别: gG; 熔断体支持件额定电压 Un: AC400V; 熔断体支持件额定电流 In: 1000A; 1P

产品标准和技术要求

GB/T 13539.2-2015

认证模式

型式试验+获证后监督

上述产品符合 CQC11-462141-2019 认证规则的要求, 特发此证。

发证日期: 2020年09月14日 有效期至: 2021年12月08日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2020年09月03日

主任: _____

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2018010308065741

NAME AND ADDRESS OF THE APPLICANT

Huanyu Group Zhejiang High Tech Co., Ltd.
Wenzhou Bridge Industrial Zone, Yueqing City, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Huanyu Group Zhejiang High Tech Co., Ltd.
Wenzhou Bridge Industrial Zone, Yueqing, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE FACTORY

Top Allied Holdings Group Co., Ltd. (V029433)
No.20 1st Zhongnan Road, Aodi Village, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

Powder-filled Cartridge Fuse
RT0-1000; Fuse-link Un: AC400V; Fuse-link In: 630A, 800A, 1000A; I1: 50kA; Breaking Range and Utilization Category: gG; Fuse-holder Un: AC400V; Fuse-holder In: 1000A; 1P

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 13539.2-2015

TYPE OF CERTIFICATION SCHEMES

Type testing+Follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462141-2019 .

Valid from: Sep.14,2020

Valid until: Dec.08,2021

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Sep.03,2020

President:

Lu Mei

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>